



ZHEJIANG YONGHE REFRIGERANT CO.,LTD.

Product: REFRIGERANT GAS R32 Batch No.: 2-2309191

Standard: HG/T 4634-2014 The date of production: OCT. 19TH, 2023

Items	Unit	Index	Inspection Results
Appearance		Colorless and no turbid	Qualified
Odor		No strange stench	Qualified
Purity	% (>)	99.90	99.96
Moisture	% (≤)	0.0010	0.0009
Acidity	(as HCL) %	≤0.0001	≤0.0001
Vapor Residue	% (≤)	0.01	≤0.01
Conclusion	QUALIFIED		
Remark	XXDA104/YH2311		

Inspector:Du Heng

Review:Ke Xuemei

Check:Chen

Yi